


INSET 01 – METER ON BYPASS
NOT TO SCALE



INSET 02 – RIVER CROSSING
NOT TO SCALE

- KEY**
- EXISTING MAINS
 - EXISTING MAINS (PRIVATE)
 - MAINS PREVIOUSLY ABANDONED
 - PROPOSED 250mm MAIN
 - PROPOSED 180mm MAIN
 - PROPOSED 125mm MAIN
 - PROPOSED 90mm MAIN
 - PROPOSED 63mm MAIN
 - MAIN TO BE ABANDONED
 - PROPOSED MAINS TO BE INSTALLED
 - EXISTING FITTINGS

NOTE:
1. UNLESS NOTED OTHERWISE ALL MAINS TO BE SDR17

- PROPOSED FITTINGS**
- SLUICE VALVE
 - WASHOUT
 - METER
 - FIRE HYDRANT
 - AIR VALVE
 - PRESSURE REDUCING VALVE

TEMPORARY WORKS/DEEP EXCAVATION
NOTE:
SUITABLE AND SUFFICIENT
TEMPORARY WORKS IN ACCORDANCE
WITH BS 5975:2008.

LENGTH OF NEW MAIN (m)				
DIAMETER	MATERIAL	SDR RATING	PROPOSED	RECORD
250 A-B	PE100	SDR17	610m	
250 C-D	PE100	SDR17	961m	
180 E-F	PE100	SDR17	364m	
LENGTH OF ABANDONED MAIN				
DATE OF FINAL CONNECTION				

NGR

ST 82144 25655

NOTES

1. ANY MAPS SHOWN ON THIS DRAWING ARE REPRODUCED FROM THE ORDANCE SURVEY MAP WITH THE PERMISSION OF HER MAJESTY'S STATIONARY OFFICE @ CROWN COPYRIGHT RESERVED, LICENCE NO, 100019539

2. UNLESS NOTED OTHERWISE ALL DIMENSIONS ARE IN MILLIMETRES & ALL LEVELS ARE IN METERS AOD

SITE CLASSIFICATION:

CLEAN-WESSEX WATER EXCAVATES

WESSEX WATER WILL:

A. IF REQUESTED AT THE APPLICATION STAGE COMPLETE ALL EXCAVATIONS WITHIN THE SITE BOUNDARY.

B. SUPPLY, LAY AND INSTALL ALL MATERIALS AND FITTINGS REQUIRED.

C. PRESSURE TEST AND CHLORINATE READY FOR SAMPLING.

D. ARRANGE FOR SAMPLING AND ORGANISE INITIAL CONNECTION ONCE PASS SAMPLE IS OBTAINED.

E. COMPLETE ANY EXCAVATIONS IN THE EXISTING CARRIAGEWAY UNDER OWN TRAFFIC MANAGEMENT, UNLESS OTHER ARRANGEMENTS ARE AGREED PRIOR TO STARTING ON SITE.

THE DEVELOPER WILL:

1. PROVIDE ACCURATE LINE AND LEVEL (MAINS DEPTH SHOULD BE A MIN. OF 900mm AND A MAX. OF 1200mm FROM CROWN OF PIPE TO FINISHED GROUND LEVEL). ANY DEVIATIONS FROM THIS FOUND AFTER INSTALLATION WILL RESULT IN CORRECTIVE WORKS BEING COMPLETED AND THE DEVELOPER LIABLE FOR ALL COSTS INCURRED.

2. PROVIDE WELFARE FACILITIES ACCESSIBLE TO WESSEX WATER EMPLOYEES.

3. COMPLETE ALL BACKFILL USING CLEAN MATERIALS AND REINSTATE WITHIN THE SITE BOUNDARY (6mm SINGLE SIZE LIMESTONE PIPE BEDDING WILL BE SUPPLIED BY WESSEX WATER FOR A STANDARD 300mm TRENCH).

4. RESPONSIBLE FOR MUCK AWAY FROM SITE WORKS.

5. TRAFFIC MANAGEMENT WITHIN THE SITE BOUNDARY.

6. ADVISE OF ANY EXISTING LIVE OR ABANDONED SERVICES FOUND TO BE CROSSING THE SITE AND WITHIN THE IMMEDIATE AREA.

7. ENSURE THAT ALL FITTINGS AND CHAMBERS IN VERGES/SOFT GROUND ARE SURROUNDED BY A CONCRETE APRON OF AT LEAST ONE SQUARE METER.

8. LATE CANCELLATION (WITHIN TWO WORKING DAYS OF THE AGREED START DATE), SITE NOT READY ON ARRIVAL WILL RESULT IN ADDITIONAL CHARGES FOR MOBILISATION/DEMOLIBISATION BEING APPLIED

NOTE:

A MINIMUM OF EIGHT WEEKS NOTICE IS REQUIRED TO START ON SITE, EARLIER ENTRY MAY BE POSSIBLE. PLEASE CONTACT THE ENGINEER IN CHARGE TO CONFIRM DATES AS SOON AS PAYMENT IS MADE

POSTCODE:

SP8 4LP

WESSEX WATER CONTACT IS AVAILABLE BY EMAILING: site541.south@wessexwater.co.uk

C	DETAILS AMENDED	RA	RM	RM	05/05/20
B	MAINS LAYOUT UPDATED	RA	RM	RM	15/04/20
A	FIRST ISSUE	JM	RM	RM	26/11/19
MK	REVISIONS	DRN	CHK	APP	DATE

PARK FARM, HAM FARM

SHAFTESBURY ROAD, DORSET

S41 NEW WATER MAIN

PROPOSED LAYOUT

APPROVED FOR ISSUE

ORIGINAL DRAWING SIZE A1		SCALES
INITIALS	DATE	1:2000
DESIGNED: RM	19/11/19	
DRAWN BY: JM	19/11/19	
DRAWING NUMBER		REV.
SQL/182404/001		C

Wessex Water

YTL GROUP

YTL